

# EC Type-Examination Certificate



according to Directive 2009/142/EC Article 8, section 1. (a)  
relating to appliances burning gaseous fuels

**Certificate No.:** MB 69243090 0001 **PIN:** 1008 CN 2627  
**Test Report No.:** 28214974 001  
**Certificate Holder:** VARA-FÉG Kft.  
H-1139 Budapest, Fáy u. 23.  
**Manufacturer:** VARA-FÉG Kft.  
H-6900 Makó, Aradi u. 136.  
**Product:** Group: Boilers with flue systems (3200)  
Gas-fired C type water heater and combined water heater  
for heating (3201, 3203)  
**Identification:** Model:  
ZC-12HE, ZC-18HE, ZC-24HE, ZC-36HE, ZCK-24HE, ZCK-36HE  
See details in Annex I.  
**Tested according to:** EN 483:1999, EN 483:1999/A2:2001,  
EN 483:1999/A2:2001/AC:2006, EN 625:1995  
**Countries of destination:** AL, BA, BG, CY, CZ, DK, EE, FI, GR, HR, HU, IT, LT, LV,  
MD, MK, NO, RO, RS, RU, SE, SI, SK, TR, UA

This type-examination certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the essential requirements of Annex I of the Directive. The Certificate Holder is entitled to use this certificate in connection with the EC Declaration of Conformity in accordance with the Directive. This certificate does not imply assessment of the series production of the product and does not permit the use of a TÜV Rheinland mark of conformity. This certificate itself does not permit the affixing of CE marking followed by the identification number of the notified body.

**Date of issue:**  
Budapest, 26.10.2012



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — [www.tuv.hu](http://www.tuv.hu)  
Notified under No. 1008 to the EC Commission

CE The CE marking may be used if all relevant and effective EC directives are complied with. CE

**Annex I to certificate No. MB 69243090 0001**

Page 1/1

PIN: 1008 CN 2627

Appliance category	Supply pressure (mbar)	Countries of destination
II <sub>2</sub> HS3B/P	H, S 25 B/P 30	HU
II <sub>2</sub> H3B/P	H 20 B/P 30	AL, BA, BG, CY, CZ, DK, EE, FI, GR, HR, IT, LT, LV, MD, MK, NO, RO, RS, RU, SE, SI, SK, TR, UA

Model	Flue system	Nominal heat output (kW)	Electrical input
ZC-12HE	C <sub>12</sub> , C <sub>32</sub> , C <sub>42</sub> , C <sub>52</sub> , C <sub>62</sub>	12	230 V AC, 50 Hz
ZC-18HE		18	
ZC-24HE		24	
ZC-36HE		33	
ZCK-24HE		24	
ZCK-36HE		33	

**Explanation:**

Z	C type with fan
C	Water heater for heating
H	Honeywell gas control unit
E	Electronic control
K	Combined

**Date of issue:**  
 Budapest, 26.10.2012


TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu



# EC Type-Examination Certificate



according to Directive 2009/142/EC Article 8, section 1. (a)  
relating to appliances burning gaseous fuels

**Certificate No.:** MB 69243089 0001 **PIN:** 1008 CN 2626  
**Test Report No.:** 28216484 001  
**Certificate Holder:** VARA-FÉG Kft.  
H-1139 Budapest, Fáy u. 23.  
**Manufacturer:** VARA-FÉG Kft.  
H-6900 Makó, Aradi u. 136.  
**Product:** Group: Gas fired boilers (3100)  
Gas-fired water heater and combined water heater for  
heating (3101, 3103)  
**Identification:** Model:  
C-12HE, C-18HE, C-24HE, C-36HE, CK-24HE, CK-36HE  
See details in Annex I.  
**Tested according to:** EN 297:1994 + A4:2004 + A5:1998 + A6:2003, EN 625:1995  
**Countries of destination:** AL, BA, BG, CY, CZ, DK, EE, FI, GR, HR, HU, IT, LT, LV,  
MD, MK, NO, RO, RS, RU, SE, SI, SK, TR, UA

This type-examination certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the essential requirements of Annex I of the Directive. The Certificate Holder is entitled to use this certificate in connection with the EC Declaration of Conformity in accordance with the Directive. This certificate does not imply assessment of the series production of the product and does not permit the use of a TÜV Rheinland mark of conformity. This certificate itself does not permit the affixing of CE marking followed by the identification number of the notified body.

**Date of issue:**  
Budapest, 26.10.2012



TÜV Rheinland InterCert Kft. – Product Certification Body – H-1132 Budapest, Váci út 48/A-B – www.tuv.hu  
Notified under No. 1008 to the EC Commission

**CE** The CE marking may be used if all relevant and effective EC directives are complied with. **CE**

**Annex I to certificate No. MB 69243089 0001**

Page 1/1

**PIN: 1008 CN 2626**

Appliance category	Supply pressure (mbar)	Countries of destination
II <sub>2HS3B/P</sub>	H, S 25 B/P 30	HU
II <sub>2H3B/P</sub>	H 20 B/P 30	AL, BA, BG, CY, CZ, DK, EE, FI, GR, HR, IT, LT, LV, MD, MK, NO, RO, RS, RU, SE, SI, SK, TR, UA

Model	Flue system	Nominal heat output (kW)	Electrical input
C-12HE	B <sub>118S</sub>	12	230 V AC, 50 Hz
C-18HE		18	
C-24HE		24	
C-36HE		35	
CK-24HE		24	
CK-36HE		35	

**Explanation:**

C	Water heater for heating
H	Honeywell gas control unit
E	Electronic control
K	Combined

**Date of issue:**

Budapest, 26.10.2012


**TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu**